

DURACOMM (MEANWELL) #SD-150B-12

DC-DC CONVERTER TEST 22 SEP 2010

LOAD A	LOAD V	INPUT V	INPUT A	EFF %
0.0	13.81	28.22	0.10	N/A
0.5	13.81	28.22	0.39	62.7
1.0	13.78	28.22	0.67	72.9
1.5	13.78	28.21	0.93	78.8
2.0	13.78	28.21	1.21	80.7
2.5	13.75	28.21	1.48	82.3
3.0	13.75	28.20	1.76	83.1
3.5	13.75	28.20	2.04	83.7
4.0	13.72	28.20	2.33	83.5
4.5	13.72	28.20	2.61	83.9
5.0	13.70	28.19	2.89	84.1
5.5	13.70	28.19	3.18	84.1
6.0	13.70	28.19	3.49	83.6
6.5	13.70	28.19	3.78	83.6
7.0	13.67	28.18	4.08	83.2
7.5	13.67	28.18	4.39	82.9
8.0	13.67	28.18	4.70	82.6
8.5	13.64	28.18	5.00	82.3
9.0	13.64	28.17	5.33	81.8
9.5	13.64	28.17	5.65	81.4
10.0	13.62	28.17	5.97	81.0
10.5	13.62	28.16	6.31	80.5
11.0	13.59	28.16	6.64	79.9
11.5	13.59	28.16	6.97	79.6
12.0	13.59	28.16	7.31	79.2